

Nutrifeed M/MP and Ammonia Reduction

Table 1: Data illustrating reduction in ammonia level and Nutrifeed MP addition rate

Date	Ammonia (mg/L) Balance Tank	Ammonia (mg/L) Final Discharge	Nutrifeed MP Addition (KG)
Day 1	230	131	2,000
Day 2	141	124	350
Day 3	278	116	325
Day 4	250	96.5	325
Day 5	-	-	-
Day 6	-	-	-
Day 7	218	69.5	3,000
Day 8	234	50	300
Day 9	460	25.5	175
Day 10	266	13.5	175
Day 11	334	10	175
Day 12	-	-	-
Day 13	-	-	-
Day 14	-	-	175
Day 15	122	0.5	125
Day 16	184	0.35	125
Day 17	110	0.61	125
Day 18	358	0.94	100
Day 19	-	-	-
Day 20	-	-	-
Day 21	188	0.71	100
Day 22	132	0.71	75
Day 23	270	0.69	75
Day 24	330	0.57	50